

AC core loss measurement on high phase angle material

Power Magnetics @ High Frequency – Eliminating the Smoke and Mirrors
Technology Demonstration Session
on 3rd March, 2018

Iwatsu Electric Company Limited
Ryu Nagahama

PRODUCTS OF IWATSU ELECTRIC

PRODUCTS (Test and Measurement Business)

- B-H Analyzer
- Digital Oscilloscope
- Curve Tracer
- Isolation System up to 500MHz BW
- Basic Measurement (DMM, Counter, Signal Generator)
- Isolation Probe
- Current and Voltage Probe




Think Important Issue for Power Loss Measurement

- Measuring method
 - Excitation method ?
 - Power Analyzer
 - B-H Analyzer
 - Digitizer
 - **Condition**
 - Temperature ?
 - Humidity ?



1. Power Loss Measurement by Power Analyzer

1.1 Issues in low power factor of the power measurement




When close to the power factor = 0,

$$P_C = I_{rms} \cdot V_{rms} \cdot \cos \theta$$

Maximum of the power error at zero power factor.

Reference N4L Application

1.2 Power Analyzer Accuracy






21 Nov 2011 17:35 Script file: Kinetiq PPA5500 low power factor test v2.01
 Automatic Calibration Environment release ACE v2.33
 NEWTONS4TH,PPA5530,00773,2.51
 Fluke,6105A,176162845,2.12

Summary report

verify power measurement at different phase angles at 220v 5A


frequency	applied	phase 1	phase 2	phase 3	VA deviation spec	W deviation spec
OK: 55.00 HZ 1.1000kVA 1.1000kw 0.000°	7 6 1.0998kVA 1.0998kw	1.0998kVA 1.0998kVA	1.0997kw 1.0998kVA	1.0998kVA 1.0998kVA	1.0998kw <-0.02%> [0.14%]	<-0.03%> [0.14%]*
OK: 55.00 HZ 1.1000kVA 1.0958kw 5.000°	7 6 1.0998kVA 1.0956kw	1.0998kVA 1.0998kVA	1.0956kw 1.0998kVA	1.0998kVA 1.0998kVA	1.0956kw <-0.02%> [0.14%]	<-0.02%> [0.14%]*
OK: 55.00 HZ 1.1000kVA 1.0833kw 10.00°	7 6 1.0998kVA 1.0831kw	1.0998kVA 1.0998kVA	1.0831kw 1.0998kVA	1.0998kVA 1.0998kVA	1.0831kw <-0.02%> [0.14%]	<-0.02%> [0.14%]*
OK: 55.00 HZ 1.1000kVA 1.0625kw 15.00°	7 6 1.0998kVA 1.0623kw	1.0998kVA 1.0998kVA	1.0623kw 1.0998kVA	1.0998kVA 1.0998kVA	1.0623kw <-0.02%> [0.14%]	<-0.02%> [0.15%]*
OK: 55.00 HZ 1.1000kVA 1.0337kw 20.00°	7 6 1.0999kVA 1.0335kw	1.0998kVA 1.0998kVA	1.0335kw 1.0998kVA	1.0998kVA 1.0998kVA	1.0335kw <-0.02%> [0.14%]	<-0.02%> [0.15%]*
OK: 55.00 HZ 1.1000kVA 996.94 w 25.00°	7 6 1.0998kVA 996.78 w	1.0998kVA 1.0998kVA	996.75 w 1.0998kVA	1.0998kVA 1.0998kVA	996.77 w <-0.02%> [0.14%]	<-0.02%> [0.15%]*
OK: 55.00 HZ 1.1000kVA 952.63 w 30.00°	7 6 1.0998kVA 952.48 w	1.0998kVA 1.0998kVA	952.45 w 1.0998kVA	1.0998kVA 1.0998kVA	952.47 w <-0.02%> [0.14%]	<-0.02%> [0.16%]*
OK: 55.00 HZ 1.1000kVA 901.07 w 35.00°	7 6 1.0998kVA 900.93 w	1.0998kVA 1.0998kVA	900.91 w 1.0998kVA	1.0998kVA 1.0998kVA	900.93 w <-0.02%> [0.14%]	<-0.02%> [0.17%]*
OK: 55.00 HZ 1.1000kVA 842.65 w 40.00°	7 6 1.0998kVA 842.53 w	1.0998kVA 1.0998kVA	842.51 w 1.0999kVA	1.0998kVA 1.0998kVA	842.52 w <-0.02%> [0.14%]	<-0.02%> [0.18%]*
OK: 55.00 HZ 1.1000kVA 777.82 w 45.00°	7 6 1.0998kVA 777.70 w	1.0998kVA 1.0998kVA	777.69 w 1.0999kVA	1.0998kVA 1.0998kVA	777.70 w <-0.02%> [0.14%]	<-0.02%> [0.19%]*
OK: 55.00 HZ 1.1000kVA 707.07 w 50.00°	7 6 1.0998kVA 706.97 w	1.0998kVA 1.0998kVA	706.96 w 1.0999kVA	1.0998kVA 1.0998kVA	706.96 w <-0.02%> [0.14%]	<-0.02%> [0.20%]*
OK: 55.00 HZ 1.1000kVA 630.93 w 55.00°	7 6 1.0999kVA 630.85 w	1.0998kVA 1.0998kVA	630.84 w 1.0999kVA	1.0998kVA 1.0998kVA	630.84 w <-0.01%> [0.14%]	<-0.01%> [0.23%]*
OK: 55.00 HZ 1.1000kVA 550.00 w 60.00°	7 6 1.0999kVA 549.93 w	1.0998kVA 1.0998kVA	549.93 w 1.0999kVA	1.0998kVA 1.0998kVA	549.93 w <-0.01%> [0.14%]	<-0.01%> [0.25%]*
OK: 55.00 HZ 1.1000kVA 464.88 w 65.00°	7 6 1.0999kVA 464.81 w	1.0998kVA 1.0998kVA	464.82 w 1.0999kVA	1.0998kVA 1.0998kVA	464.82 w <-0.01%> [0.14%]	<-0.02%> [0.30%]*
OK: 55.00 HZ 1.1000kVA 376.22 w 70.00°	7 6 1.0999kVA 376.17 w	1.0999kVA 1.0999kVA	376.18 w 1.0999kVA	1.0999kVA 1.0999kVA	376.17 w <-0.01%> [0.14%]	<-0.01%> [0.36%]*
OK: 55.00 HZ 1.1000kVA 284.70 w 75.00°	7 6 1.0999kVA 284.66 w	1.0999kVA 1.0999kVA	284.67 w 1.0999kVA	1.0999kVA 1.0999kVA	284.67 w <-0.01%> [0.14%]	<-0.01%> [0.46%]*
OK: 55.00 HZ 1.1000kVA 191.01 w 80.00°	7 6 1.0999kVA 190.99 w	1.0999kVA 1.0999kVA	191.00 w 1.0999kVA	1.0999kVA 1.0999kVA	190.99 w <-0.01%> [0.14%]	<-0.01%> [0.68%]*
OK: 55.00 HZ 1.1000kVA 95.871 w 85.00°	7 6 1.0999kVA 95.848 w	1.0999kVA 1.0999kVA	95.867 w 1.0999kVA	1.0999kVA 1.0999kVA	95.855 w <-0.01%> [0.14%]	<-0.02%> [1.32%]*

1.3 Reactor loss Measurement



1.4 Power Analyzer Accuracy for Reactor loss error

- Sin wave accuracy on the Volage
 - 0.01% Rdg+0.038% Rng+(0.004% × kHz Rdg)+5mV
- Sin wave accuracy on the Current
 - 0.01% Rdg+0.038% Rng+(0.004% × kHz Rdg)+ 300μA
- Sin wave accuracy on the Power
 - 10mHz-2MHz [0.03%+0.03%/pf+(0.005% × kHz)/pf] Rdg+0.03%VA Rng
 - 40-850Hz [0.03%+0.03%/pf+(0.005% × kHz)/pf] Rdg+0.03%VA Rng



- *Fourier series expansion for square*
 - $f(x) = \frac{4}{\pi} \left\{ \sin(x) + \frac{1}{3} \sin(3x) + \frac{1}{5} \sin(5x) + \frac{1}{7} \sin(7x) + \dots \right\}$
- *Fourier series expansion for triangle*
 - $f(x) = \frac{8}{\pi} \left\{ \sin(x) + \frac{1}{9} \sin(3x) + \frac{1}{25} \sin(5x) + \frac{1}{49} \sin(7x) + \dots \right\}$


The deskew can not be highly accurate measurement.

In this case, it can be measured by high accuracy measurement.


1.5 It is difficult to measure “Zero”. ~A problem in evaluating loss of low loss materials~

Core loss P_c when Current I and Voltage V are single sine waves;

$$P_c = I_{rms} \cdot V_{rms} \cdot \cos \theta$$




Relation between Phase error and loss measurement value error




2. Power Loss Measurement by B-H Analyzer

2.1 The principles of High-precision Core loss Measurement


- Standard : IEC 62044-3
- Japanese Industrial Standards(JIS)



SY-8218/19 adopts CROSS-POWER method that the Standards above employ.



2.2 What is the measurement principle of AC magnetic property?



Core loss per volume

$$P_{cv} = \frac{1}{A_c L_c} \frac{N_1}{N_2} \cdot f \cdot \int_0^T i_1(t) \cdot V_2(t) dt$$

$$= f \cdot \int_C H(t) \cdot \frac{dB(t)}{dt} dt$$


Magnetic field strength

$$H(t) = \frac{N_1 \cdot i_1(t)}{L_c} = \frac{N_1 \cdot V_s(t)}{L_c \cdot R_s}$$

L_c ; Effective length of magnetic path

A_c ; Effective cross-section area


2.3 Comparison of Core loss measurement by presence or absence of phase correction




There are 20% error in Power Core loss between Digitizer and Cross-Power method when the frequency is around 500kHz. This is because the frequency property between current detection resistor and each detection circuit is not compensated at the frequency axis under the Digitizer method.

CROSS-POWER method realizes the high-precision measurement.
CROSS-POWER method is adopted in IEC 62044-3.

Data by Metropolitan University



2.4 What is CROSS-POWER method ?





2.5 Comparison between Digitizer method and CROSS-POWER method

1. Both Digitizer and CROSS-POWER methods capture excitation current waveforms and inductive voltage waveforms through time sampling as the time axis waveforms (sampling data).
However, these two methods are distinguished
by the way of dealing with the time axis waveforms.
2. Digitizer method executes the time integration calculation directly as the time axis waveforms.
3. CROSS-POWER method, on the other idea
 - (1) converts the time axis waveforms into the frequency spectrum
and executes integral calculation with no phase difference
and compensates the amplitude and the phase error of current detection
sensor.
 - (2) executes the compensation of the amplitude and the phase property
of the detection circuit on the frequency axis.
 - (3) captures the time axis waveforms with little error by returning the frequency
spectrum having the error compensation to the time axis waveforms.

2.6 B-H / Core loss measurement

- B-H Analysis




Core Loss Feature

- Excitation condition


Change in Temperature

- Evaluation under a condition equal to an actual use condition


PC40 20T P_{cv} | Sample |



2.7 B-H / Core loss measurement



2.8 Constant Temperature Chamber Scanner System




2.9 Is the target Magnetic field (Current) or Flux density (Voltage) ?

1. Hm designated method:
Designate Hm (Max.Magnetic field)
2. Bm designated method:
Designate Bm (Max.flux density)
3. Current designated method:
Designate Excitation current
4. Voltage designated method:
Designate Inductive voltage


2.10 Hm method

- a. Keep measurement frequency constant and excite the sample slowly.
- b. Capture the excitation current waveform and the inductive voltage waveform and calculate magnetic field waveform by the excitation current waveform.
- c. Adjust the output voltage of power amplifier manually or automatically so that the maximum value is within the tolerance level of the targeted magnet field.
- d. After the adjustment, calculate the saturation magnetic flux density B_s , etc. with B-H curve calculated from magnetic field waveform and magnetic flux density.
- e. This method is suitable for the measurement of saturation property such as saturation magnetic flux density, residual magnetic flux and coercive force.




2.11 Bm method

- a. Keep measurement frequency constant and excite the sample slowly.
- b. Capture the excitation current waveform and the inductive voltage waveform, and calculate magnetic field waveform by time integration of inductive voltage waveform.
- c. Adjust the output voltage of power amplifier manually or automatically so that the maximum value is within the targeted magnet flux density B_m .
- d. After the adjustment, calculate time integration of multiplication of excitation current waveform by inductive voltage waveform, and then calculate core loss.
- e. Calculate the phase angle by the ratio between Core loss and Appearance power, and the permeability at Max. magnetic field H_m via Max. magnetic field and Max. flux density, ie. the amplitude ratio of permeability respectively.
- f. This method is suitable for the measurement of property for the large amplitude such as core loss, amplitude ratio of permeability, phase angle, etc.




2.12 Outline of DC bias tester


- **Fully-automatic control** is available with SY-8219 and future B-H series.
- Continuously-variable current value is available.
- DC bias non-sine wave (**chopper excitation**) is also available.
- **DC bias current of Max.30[A]** is supported.
- **Ripple current of Max.5[A]** is supported.
- Measurement frequency: **Max.3MHz(sine wave)**
- Measurement frequency: **Max.1MHz(Chopper excitation)**







2.13 Measurement method when DC bias is overlapped with toroidal core





2.14 Measurement method when DC bias is overlapped with a chip inductor





2.15 An measurement example of DC bias tester on chip inductor measurement (Pulse excitation)



2.16 Chip Inductor



2.17 Toroidal Core Inductor



2.18 DC-Bias System

Pulse & Sinusoidal with DC biasing

The image displays the physical DC-Bias System hardware and its software control interface. The hardware includes a large white unit with a digital display showing '3000', a smaller white unit with a display showing '029', and a black oscilloscope. The software interface displays 'Sample Parameters', 'Excited Conditions', 'Measured Values', and 'Configurations'.

Sample Parameters

Sample Name :	Sample	RL :	0 [Ω]
Le :	53.4 [mm]	Ve :	226.95 [mm ³]
N1 :	23	N2 :	23
Ae :	42.5 [mm ²]	We :	5 [g]

Excited Conditions

Function :	Normal
Frequency :	10 [kHz]
ΔB :	20 [mT]
Tolerance : ±	1 [%]
Duty :	50 [%]
Idc :	0.01 [A]

Measured Values

ΔPcv :	12.224 [kW/m ³]
ΔPcm :	0.5548 [W/kg]
θ :	68.279 [deg]
μΔ :	386.04
ΔB :	20.043 [mT]
ΔVL :	1.2528 [V]
ΔH :	41.317 [A/m]
ΔIL :	9.5927E-02 [A]
Hdc :	4.3071 [A/m]
ΔPc :	2.7742E-03 [W]
ΔVA :	7.4960E-03 [VA]


Configurations

Average :	16	Pod Type :	SY-960	OSC-OUT :	× 0.1
Mov-Avg :	3	Pwr Amp :	HSA4014-IW	Retry :	8

Setting Device

Full automatic test

Winding a coil Setting Measurement Conditions



Future Events and Contact us

- Contact Us

IWATSU ELECTRIC CO., LTD.

Overseas Sales Sect. Sales Dept. No.2,

7-41, Kugayama 1-Chome, Suginami-ku, Tokyo, 168-8501 Japan

TEL : +81-3-5370-5483

FAX : +81-3-5370-5492